

## ADDENDUM

This addendum contains changes for tables on pages 13 and 27 to reflect updated Drinking Water Standards through June 12, 1989.

DRINKING WATER STANDARDS AND ADVISORIES			
Chemical	State Maximum Contaminant Level	Federal Maximum Contaminant Level	National Academy of Sciences Advisory
THMs	100 ug/L	100 ug/L	--
Asbestos	--	7.1 MFL (proposed)	--
Sodium*	--	--	100 mg/L (Mod.) 20 mg/L (Sev.)
Selenium	10 ug/L	10 ug/L (current) 50 ug/L (proposed)	
Pesticides		Listed in Table 1, Page 27.	
* The National Academy of Sciences advises a maximum of 100 mg/L for people who must restrict their sodium intake to a moderate degree and a maximum of 20 mg/L for those who must severely restrict their sodium intake.			
ug/L = micrograms per liter			
mg/L = milligrams per liter			
MFL = million fibers per liter			